

PV TEST CERTIFICATE

CERTIFICATE:
ELIOCERT ID20180702

REPORT N°:
20180620-170047 FINALE24-RAP-01
20180627-170066 FINALE24-RAP-01

LICENSE HOLDER:

EVOCELLS

Rue du Val d'Or, 1C
5374 Maffle
Belgique

MODULE TYPE/ PRODUCT:

Performance **262 to 318*** (step of 1 Wp)
Design **253 to 307*** (step of 1 Wp)

* The tested module references are the Performance 290 Wp and the Design 280 Wp
The above stated power ranges already consider the 10% margin according to the applicable IEC6EE retesting guide lines and can not be extended further.

MANUFACTURING PLANT:

EVOCELLS

Zone d'activité Nord 89
5377 Baillonville
Belgique

TRADEMARK:



BASIS OF QUALIFICATION:

This certificate establishes that all the required tests of the related tests schemes from the standards detailed below were passed according to their regulation of the pass criteria.

IEC 61215 - Design qualification and type approval of photovoltaic modules (First edition - 2016-03)

- Part 1 : Test requirements
- Part 1-1: Special requirements for testing of crystalline silicon photovoltaic modules
- Part 2: Test procedures

IEC 61730 - Photovoltaic modules safety qualification (First edition - 2016-08)

- Part 1: Requirements for construction
- Part 2: Requirements for testing

IEC TS 62915 - Photovoltaic modules - Type approval, design and safety qualification - Retesting



ELIOCERT ID20180702

APPLICATION CLASS:
MAXIMUM SYSTEM VOLTAGE:

A
1500 VDC

SAFETY CLASS:
CERTIFICATE VALIDITY PERIOD *:

II
01/07/2023

* The certificate validity is linked to a valid Eliosys annual factory inspection certificate for the associated manufacturing plants.

REMARKS:

The above listed PV modules fulfill the requirements of Application Class A (Safety classe II).
They may be used in PV plants at a maximum system voltage of up to 1500 VDC.
The fire test (IEC 61730-2/MST 23) was not performed.

CONDITIONS:

The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type. Further details on certified models in the constructional data form : 20180124-170047 Finale 24 Evocells-ENR-App certif-Quali Black Frame Performance-290
20180124-170066 Finale 24 Evocells-ENR-App certif-Quali Full Black Frame Design-280

Technical data, materials and components description are into the indicated test report. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

THIS CERTIFICATE IS ISSUED BY:

DATE: 02/07/2018



HEAD OF TESTING LABORATORY
THIBAUT BOULANGER

C.E.O.
JULIEN THIRY